

Addendum #2



Project Information

Project Name:	Sheep Draw Trail At 83rd Avenue
Bid Number:	F24-01-004
Date:	January 24, 2024
Project Manager:	Dave Wells

Addendum Items, Questions and Answers

Item 1	Replace Section 00120 Bid Proposal added by Addendum 1 with the attached Section 00120 Bid Proposal. The attached Section 00120 Bid Proposal has the correct (revised) Contract Time of 120 Calendar Days.
Question #1	Will the city be purchasing the concrete, or will that be up to the concrete contractor?
Answer	The City is not supplying concrete.
Question #2	Is there a site to dispose of Rip rap, muck, concrete and asphalt?
Answer	The City is not providing a site for waste materials.
Question #3	On the muck excavation line, is the 57 rock used to replace the muck part of that line or is it a separate line item?
Answer	Aggregates for muck replacement have separate pay items.
Question #4	There is graffiti on the existing abutment is that to be removed? If so is that an addendum?
Answer	Graffiti removal is not included in the Work.
Question #5	On page 5 of the plans it shows the existing sidewalk is staying, but on page 7 it says to remove the side walk. what is getting removed and what is getting left?
Answer	Sidewalk removal under the bridge is in the bid schedule quantities and is noted on Sheet 7 as it may have to be removed. This will be determined by the Engineer after it has been exposed. If it is not removed, the estimated quantity will be deleted from the Contract by Change Order.
Question #6	On page 7 of the plans it calls to remove some storm pipe, what size is it?
Answer	The existing storm pipe is 24" CMP.
Question #7	Are there any flow rates on the water?
Answer	Sheepdraw base flows have not been measured. The flow rates vary seasonally and may be impacted by agricultural irrigation. Sheepdraw floodplain hydrology is available and is presently being restudied. The bridge design flow was 4090 CFS (100-YR). The 2-YR was 335 CFS.

Section 00120

BID PROPOSAL

PROJECT: SHEEPDRAW TRAIL AT 83RD AVENUE - #F24-01-004

The Undersigned, having become familiar with the local conditions affecting the cost of the work, plans, drawings, and specifications attached herewith, and with advertisement for bids, the form of bid and proposal, form of bond, all of which are issued and attached and on file in the office of the Project Manager, hereby bid and propose to furnish all the labor, materials, necessary tools, and equipment and all utility and transportation service necessary to perform and complete in a workmanlike manner all of the work required in connection with the construction of the items listed on the bidding schedule in accordance with the plans and specifications as prepared by the City of Greeley, Colorado, for the sums set forth in the Bidding Schedule.

The total bid shall be the basis for establishing the amount of the Performance and Payment Bond for this project. The total bid is based on the quantities shown in the bid proposal form and the dimensions shown on the plans.

The undersigned has carefully checked the Bidding Schedule quantities against the plans and specifications before preparing this proposal and accepts the said quantities as substantially correct, both as to classification and the amounts, and as correctly listing the complete work to be done in accordance with the plans and specifications.

The undersigned, agrees to complete and file a Performance and Payment Bond and further agrees to complete the contract within one hundred twenty (120) Calendar Days from Notice to Proceed. Official notice to proceed will not be issued until adequate Performance and Payment Bonds and other required documents are on file with the City of Greeley.

NOTE: Bidders should not add any conditions or qualifying statements to this bid as otherwise the bid may be declared irregular as being non responsive to the Invitation for bids. The following numbered Addenda have been received and the bid, as submitted, reflects any changes resulting from those Addenda: _____

ATTEST

DATE

COMPANY NAME

BY

SIGNATURE

TITLE