

Addendum #1



Project Information

Project Name: Greeley West Park Playground for Culture, Parks and Recreation Department/Parks Division

Bid Number: RFP #FW21-09-158

Date: September 24, 2021

Project Manager: Clint Anders

Addendum Items

Question #1

To what thickness and standards should the concrete walks be built to? [New sidewalks should be 6" thick and built to City of Greeley Construction standards.](#)

https://greeleygov.com/docs/default-source/construction-standards/streets/cog-corridor-stds_row-features.pdf

The sidewalk layout does not need to be exactly what is shown in the concept plan. There is room for some creativity here as long as it meets ADA requirements. For example, another idea I had was a concrete curb with a bonded rubber path. Not sure if that is cheaper than a concrete sidewalk but just an idea to expand the play footprint a bit more. The conceptual layout is just a solution that requires minimal irrigation and landscape repairs.