

Addendum #1



Ice Haus Compressor Maintenance

Project Information

Project Name:	Ice Haus Compressor Maintenance RFP
Bid Number:	RFP #FS21-02-041
Date:	March 11, 2021
Project Manager:	Mark Mann & Amanda Gustafson

Addendum Items

Item 1	Exhaust fans are not on the list of equipment but since they are part of the system, are suppliers/vendors to cover the fans and dampers? Fans and dampers to be included on the equipment list.
Item 2	If after the yearly Brine analysis is done and there is an adjustment to be made, are costs billable or part of the contract? Does this also apply to the Glycol in the system? If additional NH3 is required, is it also billable? The cost of the brine, glycol, and ammonia would be billable.
item 3	Per the two Vilter compressors, it stated to replace (1) suction and discharge valve. Is there a record of valves that have been replaced? There was a top end done on both compressors in 2019.