

# Addendum #1



## Capital Project Committee

### Project Information

Project Name:	2020 Pavement Crack Seal Program
Bid Number:	RFP #FD20-01-300
Date:	February 7, 2020
Project Manager:	Pat Hill

### Addendum Items

Item 1:	Is a Street Sweeper required? - <a href="#">City to provide</a>
Item 2:	Is it required to use Colorado Employees? <a href="#">Employee's must meet legal requirement of the State of Colorado.</a>
Item 3:	What is your start and substantially complete dates? By Middle of March(depending on weather) and through June depending on temperatures. Also there might be an opportunity for additional work in the Fall from October to December
Item 4:	Do you have any bid tabs from when this previously bid? <a href="#">The City did it with internal crews over the last ten years.</a>
Item 5:	Is there a 5% added to our bid where we are in UT? <a href="#">No</a>
Item 6:	Can liquid spray on materials like Glensoil be used as a blotting material during crack seal operations. <a href="#">Detac is what our city crews are using. We will more than likely approve others.</a>
Item 7:	Is the City requiring the use of a heat lance on all cracks to be sealed? <a href="#">Yes</a>
Item 8:	Will the successful low bidder be determined by combining the costs for the "Blow and Go" and the "Rout and Seal" processes together? <a href="#">Yes, the low bidder will be a combination of the two prices.</a>
Item 9:	All of the streets listed in the bid documents are noted to use the "Blow and Go Process" for crack seal. What is the potential additional quantity using the "Rout and Seal Process"? <a href="#">Still to be determined by the City</a>