

Addendum #1



Capital Project Committee

Project Information

Project Name:	Centerplace Turn Lane Improvement - Phase II
Bid Number:	FD21-01-003
Date:	January 21, 2021
Project Manager:	Brian Ward

Addendum Items

Item 1	Due to the corona-virus, the City is requiring the following for submitting bids and the opening of bids:
	see attached instructions for submittal of bid responses
	CHANGE IN BID SUBMITTAL TIME - Please submit bids before 2:30pm MST
	See below for Bid Opening Instructions - Thursday, January 28, 2020 at 2:30pm
	Join Zoom Meeting https://greeleygov.zoom.us/j/85011059106 Meeting ID: 850 1105 9106 Passcode: 902830 Dial by your location +1 253 215 8782 US (Tacoma) +1 346 248 7799 US (Houston) +1 669 900 6833 US (San Jose)
Item 2	Clarifications:
	Stormline will need to be camera'd before and after construction at the cost of the contractor
	Traffic pole, or any portions thereof, may be salvaged and not replaced in full, at the discretion of the City
	Traffic control may be night and the contractor should bid for the worst case scenario
	NTP can be issued as soon as the contracting for the the project is finalized or as soon as March 1.
Item 3	Asphalt substitution of 64-22 for 76-28 is acceptable.
	Can the asphalt mix for this project be changed from PG76-28 to PG 64-22? The low quantity of the polymer modified HMA will drive the per ton cost well above budget. Yes
Item 4	Will night work be required for signal operations? Yes, potentially

Bid Responses will only be accepted electronically during the COVID-19 event.

Instructions for electronic submittal.

Email your Bid Response to purchasing@greeleygov.com. Submit your Bid response to this email only – please do not email to multiple people. Only email's sent to purchasing@greeleygov.com will be considered as responsive to the invitation to bid. Emails sent to other City emails may be considered as non-responsive and may not be reviewed.

Bids shall be submitted in a single Microsoft Word or PDF file under 20MB

The Bid number and Project name **must be noted** in the subject line, otherwise the Bid may be considered as non-responsive to the Bid.

Electronic submittals will be held, un-opened, until the time and date noted in the Bid documents or posted addenda.