

Addendum #3



Capital Project Committee

Project Information

Project Name:	Recreation Center & Family Funplex Pool Lighting / Painting
Bid Number:	FD20-03-051
Date:	April 13, 2020
Project Manager:	Dale Blehm

Addendum Items

Item 1:	The paint scope states "Provide at least 2 coats to cover the existing paint colors, confirmed with the owner." The CMU specs to use block filler, intermediate coat and finish coat. Is it necessary to use 3 coats on the CMU walls or do you only want two? No needed for block filler on existing CMU wall with existing painting, City will require 2 coats of new paint color, approved by owner for coverage of existing paint color.
Item 2:	In regards to the lighting and paint project, is it possible for me to access the sites or at least walk the sites in order to determine the amount of clearance that I would have to bring in my scaffolding and/or lifts. If not, are you able to confirm what the max clearance is for the sites? (i.e. single or double door height and width) Additional site visits can be schedule with Project Manager. Call 970/539-6230 to schedule, deadline for site visit April 14 by 12:00 pm.
Item 3:	Please confirm that you want the Lighting and Painting to go under one company and they will not be separate bids. For example run under a GC. City of Greeley is looking for a General Contractor to complete this project, City will not except bids from electrical and painting sub-contractors only.
Item 4:	Please confirm that the double doors at the rec center have direct access to the outside for equipment access? Rec.Center has double doors on northwest and northeast side to pool area with removal centers.City has used a smaller scissor lifts on in the past.
Item 5:	Please confirm the bleachers at the rec center collapse against the wall? Rec.Center pool bleachers collapse back against the wall on south side of pool area.
Item 6:	Are there any load restrictions for the surfaces where scaffold or equipment will placed for accessing the work?(both locations) Load restrictions in pool bottoms shall be no more than scaffolding with wheels. Pool decks shall be limited to 7000 lbs., deck thicken is 4" to 6" with wire.
Item 7:	What is the degree(percentage) of elevation change in the pool depths as rolling scaffold and scissor lifts can only be utilized on flat level surfaces? Elevation change is 1% to 2.5% in 90 Feet. The city has used scaffolding in pool bottom with adjustable wheels in the past. Contractor must protect pool bottom from damage at all times in both facilities.
Item 8:	Confirming that the warranty of this project for the painting and the lighting is for 2 years? City of Greeley requires a 2 year warranty on all city project, general contractor must provide 2 year warranty on these projects.

Item 9	Confirming that at the Greeley Rec Center all conduit must be removed and new EMT conduit installed. Each light will be pendant hung. The painter will then need to tape off the lights and paint the conduit and stems? All lighting electrical conduit must be removed and new EMT installed, each light will be pendant hung. The painter must tape off the lights and paint all conduit and stems.
Item 10	Confirming no alternates for lighting are being accepted? No alternates for lighting fixtures over the pool area will be accepted. Fixture specifications are on the electrical drawings.
Item 11	At the Greeley Fun Plex there was comment that the lights over the water slide me change. Is there a specification or part number for that light. Alternate for Type C slide tower wall packs, See attached Spec. sheet for new 50W fixtures.
Item 12:	Due to the corona-virus, the City is requiring the following for submitting bids and the opening of bids:
<p>A) see attached instructions for submittal of bid responses</p> <p>B) For the bid opening: bids will be open via a tele-conference. Please see below:</p> <p>Join Zoom Meeting https://zoom.us/j/98044939816</p> <p>Meeting ID: 980 4493 9816 Password: 597660</p> <p>Dial by your location +1 253 215 8782 US +1 301 715 8592 US</p>	

Bid Responses will only be accepted electronically during the COVID-19 event.

Instructions for electronic submittal.

Email your Bid Response to purchasing@greeleygov.com. Submit your Bid response to this email only – please do not email to multiple people. Only email's sent to purchasing@greeleygov.com will be considered as responsive to the invitation to bid. Emails sent to other City emails may be considered as non-responsive and may not be reviewed.

Bids shall be submitted in a single Microsoft Word or PDF file under 20MB

The Bid number and Project name **must be noted** in the subject line, otherwise the Bid may be considered as non-responsive to the Bid.

Electronic submittals will be held, un-opened, until the time and date noted in the Bid documents or posted addenda.

Guardian Compact Series



LED WALL PACK

The EverLast Guardian Compact LED wall pack fixture provides substantial light from a small package. Utilizing chip on board (COB) technology, multiple LED chips are bonded directly to the substrate to form a single module. This packaging takes less space and obtains the full potential of the LED chips. Simple installation into new or existing applications is made easy thanks to its small form factor. Another benefit of this LED wall pack fixture is that it offers a warm, consistent lighting solution for any outdoor, vertical space.

Backed by EverLast's 10 year limited warranty

SUMMARY

LumenOutput:
30W: 3,150* Lumens @5000k
50W: 5,200* Lumens @5000k
80W: 8,000* Lumens @5000k
Cree LED (COB) Emitters
1-10v Dimming
10kV Surge Protector (Standard)
DLC**
ETL to UL 1598
IP65 Rated For Natatorium Use
Temperature Rated: -40°f to 104°f
Cutoff: Standard Cutoff

*Lumen output varies based upon kelvin ratings

**For current DLC and DLC Premium qualified versions available, please visit <https://www.designlights.org/search/>



FIXTURE DIMENSIONS

Wattage	Length	Width	Height	Weight
30w	6.3" (16.00 cm)	7.8" (19.8 cm)	4.3" (11.00 cm)	4 lbs
50w	11.8" (29.95 cm)	10.8" (30.00 cm)	6.0" (15.1 cm)	13.6 lbs
80w	11.8" (26.00 cm)	10.8" (30.00 cm)	6.0" (15.1 cm)	13.6 lbs

TOTAL CURRENT (amps) / FIXTURE

Wattage	120V AC	240V AC	277V AC
30w	0.25	0.12	0.11
50w	0.41	0.20	0.18
80w	0.66	0.33	0.29

ORDERING INFORMATION

BASE MODULE

EL-LED-GDC	30	UL	X	50	CO
FIXTURE	WATTAGE	VOLTAGE	DIMMING	COLOR TEMP	CUTOFF
EL-LED-GDC	30	UL 120-277V AC	X NONE	40 4000K	STANDARD
	50		D 1-10V	50 5000K	
	80				



GUARDIAN SERIES LED WALL PACK ACCESSORIES

OPTIONAL ACCESSORIES

AUB-GDC



Adjustable U-Bracket.
Designed for use on flat surfaces while still offering angled positioning.

BTN1



Button Photocell for use in 120V applications

BTN2



Button Photocell for use in 208V-277V applications

PRODUCT IMAGES

