



SITE CERTIFICATION

NOT REQUIRED FOR ADDITIONS AND REMODELS

DATE: ADDRESS: PERMIT#

LOT: BLOCK: SUBDIVISION:

The relative elevations at the above referenced address were measured at the lot sides and corners, top of foundation, and other locations as shown or needed and are within 0.15 foot tolerance of the approved plot plan elevations.

Please answer the following questions by initialing the following statements and submit the completed form for City approval only when you have confirmed conformance. INCOMPLETE FORMS WILL NOT BE ACCEPTED:

The top of window wells at this home are a minimum of six inches (6'') above the ground surface adjacent to the window wells. (Allows for sod or mulch installation.) Yes

The flow lines of drainage swales and my measured elevations shown on the plot plan, at this home, are a minimum of 6 inches below the elevation of soil adjacent to the structure and will direct drainage as shown on the City approved plot plan. Yes

A copy of the City approved plot plan with my measured (circled) corner, side lot elevations and any other elevations as shown on the City approved plot plan is attached to this certification. Yes

Down spouts are installed and all down spouts in the front point towards the front; down spouts in the back point towards the back; down spouts in the middle are piped and directed to the front or back.*

*Downspouts may be allowed to discharge towards the side lot line if they are not directed toward a window well on the adjacent lot. Yes

Lot grading does not extend beyond property limits. Yes

I realize City staff may need 48 hours to review and approve Certificate of Occupancy for this lot. Yes

Engineering/Surveying Firm Name Phone Builder Contact Name Phone

Firm Address

City State Zip

Signature of Engineer/Surveyor Seal