

# Fire Service

**Fire Hydrant Analysis**  
Cost to Fully Meet Current Standards

Service Level	# of Locations	Cost Each	Total
Level 2 - Partially Meets Standards	18**	\$7,500.00	\$135,000.00
Level 3 - Does Not Meet Standards	4	\$7,500.00	\$30,000.00
<b>Total</b>			<b>\$165,000.00</b>

\*\* An additional 6 Level 2 service areas will be upgraded when the adjacent Level 3 service area is addressed

- Areas Covered by the additional hydrants
- Sherwood Village Apartments area covered by two private hydrants

## Greeley Urban Renewal Authority 10th Street Project

### Fire Service Availability

City of Greeley  
Weld County, Colorado

#### Legend

- |   |                                      |                         |              |
|---|--------------------------------------|-------------------------|--------------|
| <b>Fire Service Availability</b>  | Neighborhood Boundaries              | Roads                   | Structure    |
| <b>93.9%</b> 1 Meets Standards (Hydrant distances up to 300')                       | Parcels                              | Bridges                 | Park Lands   |
| <b>5.8%</b> 2 Partially Meets Standards (Hydrant distances from 301' to 400')       | Fire Hydrant                         | Public Schools          | Water Bodies |
| <b>0.3%</b> 3 Does Not Meet Standards (Hydrant distances of 401' or more)           | Private Hydrant                      | Colleges & Universities |              |
| Sherwood Village Apartments   | Proposed Additional Hydrants         |                         |              |
| <b>Hoses are typically routed along curb lines rather than taking direct paths.</b> | Areas covered by additional hydrants |                         |              |

# 5

Created: 5/21/2004 Map Scale: 1" = 350' By: The GIS Program File Name: 10thStProj\_FireService.mxd  
 Information contained on this document remains the property of the City of Greeley. Copying any portion of this map without the written permission of the City of Greeley is strictly prohibited. All planimetric data was digitized from aerial photographs dated 1987, 1992, 1995, and 2000. Updates are continual and data representations will change over time. This product is not necessarily accurate to engineering or surveying standards but does meet National Mapping Accuracy Standards (NMAAS). The information contained within this document is not intended to be used for the preparation of construction documents.