



**NOTES:**

1. SEE REQUIREMENTS FOR UTILITIES IN CITY OF GREELEY WATER & SEWER DESIGN CRITERIA & CONSTRUCTION SPECIFICATIONS
2. REFER TO CITY OF GREELEY WATER & SEWER DETAIL W-9 FOR POTABLE WATER METER, CURB STOP, CORP STOP SERVICE DETAILS

3. TRACER WIRE IS REQUIRED FOR ALL NON-METALLIC PIPES LOCATED ON TOP OF PIPE AND TAPE A MAX OF 10 FOOT SECTIONS
4. ONE UNDERGROUND WIRE SPLICE IS ALLOWED AND SHALL BE IN A GEL CAP SPLICE KIT SUITABLE FOR UNDERGROUND INSTALLATION.
5. FOR SERVICE STUBS FOR FUTURE CONNECTIONS PROVIDE A MINIMUM OF 2 FEET OF WIRE WRAPPED AND TAPED TO MARKER POST AT PROPERTY LINE

**LEGEND**

- W — WATER MAIN/ SERVICE
- SS — SAN. SEWER MAIN/ SERVICE
- - - - - PROPERTY LINE



TYPICAL METER AND SERVICE LOCATING DETAIL  
DETAIL WS-4

DATE: OCTOBER 2018

SCALE: N.T.S.