

Addendum #1



Project Information

Project Name:	16th Street Storm Main Rehabilitation Consulting Services for Public Works/Stormwater Management Division
Bid Number:	FW21-11-182
Date:	November 17, 2021
Project Manager:	Andrew Fisher

Addendum Questions

Question #1	Was Getotech work done to to the overlay in 2017?
Answer	No Geotech investigation was completed to support the 2017 Overlay of 16th Street.
Question #2	Is the Lithos study available for review?
Answer	This document has been released with Addendum #1.
Question #3	What is wrong with the 60" storm drain that was replaced?
Answer	The 60" that was replaced in 2017 in the greenbelt upgradient of the 16th Street line was suffering from some collapse, ovalization, gapped joints and sink holes appearing above the pipe. Once pipe bedding was determined to be an issue, the pipe and bedding was replaced via open trench. There are no known issues with the 2017 replacement at this time.
Note 1	Firms are reminded that the inquiry deadline is Friday, November 19 at 4pm . Please direct any questions to Purchasing@GreeleyGov.com and include FW21-11-182 in the subject heading
Note 2	Firms are reminded that the proposal due date is Wednesday, December 1 at 2pm . Please submit proposals directly to Purchasing@GreeleyGov.com and include FW21-110182 in the subject heading.