

Addendum #2



Project Information

| | |
|-------------------------|--|
| Project Name: | 11th Avenue Traffic Signal Upgrade Project |
| Bid Number: | F24-04-033 |
| Date: | April 23, 2024 |
| Project Manager: | Scott Logan |

Addendum Questions

| | |
|--------------------|--|
| Question #1 | Is it intended that we need to tie-in new bored conduit to existing signal pole caissons? Do we need to use the existing conduit stubs out of the caissons, or can this be done external to the caisson? |
| Answer | The tie-ins will be at the existing conduits out of the caisson. |
| Question #2 | If we believe some of the quantities to be off (potholing, uniformed traffic control), should we assume the quantity we believe is needed, since the project bid items are all lump sum? |
| Answer | Assume that the project plans include approximate quantities. The contractor is responsible for quoting actual quantities that they believe are needed for the project. |
| Question #3 | If concrete items overrun, will they be paid for, or because the bid is lump sum, should it all be included? |
| Answer | This is a lump sum bid shall include all of the concrete sidewalk, ramp, and other work. Any overalls are included in the lump sum bid item. |
| Question #4 | Can it be confirmed that the city will be providing the wiring as it is listed as install only? |
| Answer | Yes, the city will be providing the wiring as it is listed as install only. |
| Question #5 | Can a pay item for the pedestal pole caissons be added to the bid schedule? |
| Answer | This is a lump sum bid for signal work at each intersection. No pay item will be added for this project. |
| Question #6 | How much time is expected to be used for each pothole? |
| Answer | Time to pothole for utilities is subject to contractor's discretion. |