

**PERMIT FACT SHEET
ANCHOR POINT RV & BOAT STORAGE**

PERMITTEE INFORMATION

Name and Address:

Anchor Point RV & Boat Storage
10800 Hwy 257 Spur
Greeley, CO 80634

Description of Operation:

This is a self-storage rental unit business. The facility also operates a RV chemical toilet dump station for tenants only. This permit is primarily focused on the RV dump station.

Wastewater-Generating Processes:

Domestic wastewater is generated from toilets in the main building. The RV dump station generates domestic wastewater. The domestic wastewater from RV's may contain deodorizing chemicals similar to those used in potable toilets.

Sewer Connections:

Outfall 01

6 inch main lateral sewer that services the force main for the office building at 10800 Hwy 257 the outfall is the connection to the public sanitary sewer manhole 08-22.060.

Outfall 02

4 inch self closing hatch cover and sewer southwest of the office building that services the RV chemical toilet dump station and connects with the main building lateral sewer

Categorical Determination:

Not applicable.

PERMITTEE DISCHARGE SUMMARY

Pollutant Quantities:

<u>Pollutant</u>	<u>Daily Avg.</u>
Flow	estimated 130 gallons/month

PERMIT LIMIT BASIS

Permit Application Documents:

The permit application was submitted on October 28, 2019. The application is located in Anchor Point RV & Boat Storage file.

Enforcement Summary

An annual summary of violations and enforcement activities is located in the Anchor Point RV & Boat Storage file.

Literature References:

EPA's "Guidance Manual on the Development and Implementation of Local Discharge Limitations Under the Pretreatment Program", was used in developing local limits.

PERMIT CONDITION DEVELOPMENT RATIONALE

Discharge Volume

estimated 130 gallons/month

Monitoring Requirements:

Outfall 02

<u>Parameters</u>	<u>Frequency</u>	<u>Type</u>
Name	each discharged load/month	personal or business
Vehicle license #	each discharged load/month	personal or business
Flow (gallons)	each discharged load/month	holding tank volume
Date	each discharged load/month	day/month/year
Signature/certification	each discharged load/month	personal

"Holding Tank Volume" is either a numerical value provided by the holding tank

manufacturer, a volume derived mathematically, or a measured volume derived from a meter or other calibrated device. The holding tank volume will be considered the discharged load volume regardless of whether or not the holding tank was full prior to the discharge.

Reporting Requirements:

The recorded information documented in Part 2. A, must be submitted on the RV Waste Dump Station Sign-in Sheet(s), Part 9. The sign-in sheets shall be submitted with a Self-Monitoring Compliance Report Form, Part 8. The report shall be signed and submitted to the office of the Control Authority on or before the end of the following month.

Non-complying reports are required to be reported within 24 hours of becoming aware of the violation. . A statement outlining which corrective actions will be performed to bring the discharge into compliance is also required within 5 days of the detected violation. An advanced notification of any substantial change in the volume or character in the wastewater discharge is also required.

Special Requirements

Best Management Practices (“BMP”) are required due to past episodes in which RV discharge hoses have accidentally disconnected from the RV holding tank during the discharge and then fell into the RV dump site pipe causing sewer obstructions in the City’s downstream sewer. The City has developed the following BMP’s as a response to a sewer blockage.

The permittee shall implement the following Best Management Practices:

- a. The dump station is only available during gate hours
- b. Tenants must complete and sign the required dump form when using the dump station. The following statement will be printed in bold letters on the form: “If at any time during the dump of sewage that any foreign item (hose, trash, etc.) goes into the dump sewer, you are to terminate the flow and report it immediately to the Anchor Point RV & Boat Storage staff.”
- c. If a tenant notifies Anchor Point RV & Boat Storage staff that a foreign object was dumped in the sewer, the tenant or Anchor Point RV & Boat Storage staff will try to retrieve the item. If this is not possible, The Anchor Point RV & Boat Storage staff will inform the facility manager on duty of the foreign object discharge incident. The facility manager shall report by telephone (350-9363, 350-9360, 336-4247 Monday-Friday 7:00 a.m. through 4:00 p.m. or 396-3827, 371-3737 after hours) to the City of Greeley Sewer Department directly upon receiving this information to notify City staff of the incident.
- d. Anchor Point RV & Boat Storage staff must perform a visual check of the dump station during high volume periods to ensure that nothing has been misplaced down the dump sewer.

Local Limits:

Unless specifically provided elsewhere in this permit, the permittee shall not introduce or cause to be introduced into the POTW the Prohibited Discharge Standards of Section 14.11.070 of the Greeley Pretreatment Chapter. The Prohibited Discharge standards are found in Appendix A of the permit.

DRAFT